

Request for Information (RFI): No. 1

Project: Western District of NC US District Courts Solicitation No 15 – Charlotte Courtroom #2 Redesign

Contact: Kent Creasy (TCOR) [Kent\\_Creasy@ncwd.uscourts.gov](mailto:Kent_Creasy@ncwd.uscourts.gov)

1. Section C3.1 Area Requirements:

A. Judge:

1. Ref item 4: Local audio monitor is to be mounted underneath the Judge's bench. Please confirm. **Confirm**
2. Ref item 5: Mount "new" 22" LED display similar to the existing display. Utilize the GFE pole mount. Please confirm. **Confirm**

B. Clerk:

1. Ref item 3: Local audio monitor is to be mounted underneath the Clerk's bench. Please confirm. **Confirm**
2. Ref item 7: Provide three (3) line level audio feeds for recordation and streaming usage from the audio DSP (digital signal processor Biamp Tesira) at the Clerk's location. **Confirm**

C. Reporter:

1. Ref item 1: Local audio monitor is to be mounted underneath the Reporter's bench. Please confirm. **Confirm**
2. Ref item 3: Provide one (1) microphone level audio feed recordation usage from the audio. Please confirm. **Confirm**

D. Witness:

1. Ref item 2: Local audio monitor is to be mounted underneath the Witness' bench. Please confirm. **Confirm**

E. Prosecution:

1. Ref item 1: Please confirm that the required IPAD and all applicable Apps will be the GFE. **Confirm**
2. Ref item 2: Please confirm a total of two (2) microphone interconnects at the Prosecution table for AVC (Audio Visual Contractor) provided microphones. **Confirm**
3. Ref item 3: Please confirm a total of two (2) microphone interconnects at the Prosecution table for aux microphone capability. **Confirm**

F. Defense:

1. Ref item 1: Please confirm that the required IPAD and all applicable Apps will be the GFE. **Confirm**
2. Ref item 2: Please confirm a total of two (2) microphone interconnects at the Defense table for AVC (Audio Visual Contractor) provided microphones. **Confirm**
3. Ref item 3: Please confirm a total of two (2) microphone interconnects at the Defense table for aux microphone capability. **Confirm**

G. Jury:

1. Ref item 1: Confirm desire to have the AVC provided boundary microphones mounted on or at each of the Jury displays. **Confirm**
2. Ref item 2: It was discussed that the AVC is to provide wall mounting device, one (1) for each of the four (4) displays servicing the first row of jurors. It was further discussed that the owner must provide an acceptable mount backing for each display mounting bracket. If a suitable mount backing cannot be provided, the AVC will provide a pole mounted solution for these displays. Any additional cost for the alternate pole mount solution will be the responsibility of the owner via change order. **Correct**

3. Ref item 3: AVC to provide a new 70v power amplifier to power the GFE speakers housed in the jury box and single overhead "sphere" speaker. **Confirm**
- H. Audience:
1. Ref item 2: AVC to provide an automated display lift for a 60" or larger display. The lift should match, as best as can be provided, the existing décor within the courtroom. The lift is also to provide a mounting base/solution for a second GFE provided Vaddio ClearView HD19 video camera to support the videoconference requirements. The camera should be mounted within or on top of the automated display enclosure. **Confirm**
- I. General/Shared Equipment:
1. Ref item 4: Owner states that the four (4) desktop wireless microphone/transmitters should be boundary microphone elements. **Confirm**
  2. Ref item 6: Owner states that the number of assistance listening headset/receivers provided by the AVC should be four (4). **Confirm**
  3. Ref item 7: Owner states that the number of press feeds to be provided is one (1) and that this feed is to be microphone level. **Confirm**
  4. Ref item 8: Owner states that the GFE Polycom HDX9000 CODEC and camera are not currently under a Polycom (or other) maintenance agreement. Please confirm. The AVC shall not be responsible for these devices as to functionality, software revision, or serviceability. During installation, the owner is responsible to ensure these devices are properly working and will not hold the AVC responsible for any delay in completion, system testing, nor system sign off due to Polycom CODEC/video camera issues. **Confirm**
  5. Ref item 8(a): GFE provided Vaddio ClearView HD19 HD PTZ camera - Owner states that the HD PTZ camera is not currently under a maintenance agreement. Please confirm. The AVC shall not be responsible for this device as to functionality, software revision, or serviceability. During installation, the owner is responsible to ensure this device is properly working and will not hold the AVC responsible for any delay in completion, system testing, nor system sign off due to camera issues. **Confirm**
  6. None of the GFE equipment to be used within this project design is to be part of the required warranty and service conditions of this bid. **Confirm**
  7. Owner agrees to provide any required electrical service, network drops, CATV/SAT drops, and blocking for mounting equipment as may be necessary. **Solicitation requires all aspects of project be provided by the AVC.**
  8. Owner agrees to provide any provisioning all applicable network and telephone connectivity for network, video and audio conferencing use. **Confirm**
  9. Owner agrees to provide all IP addresses and network setup information required for the purposes of configuring any A/V devices that will be connected to the owner's network. **Confirm**
  10. Owner agrees to provide any GFE devices to the AVC prior to the date of site installation for testing purposes. **Confirm**